

Distributed PV and HELCO Operations

Impacts and Actions




Lisa Dangelmaier
Hawaiian Electric Light Company

December 1, 2010


Overview of HELCO System

- Small autonomous system (no interconnections)
 - daily minimum 85-95 MW
 - day peak 155-165 MW
 - eve peak 180-195 MW (evening peaking)
- High costs
- Close to limits of stable operation
- High penetration of variable generation
- High penetration of distributed generation
- Large amount of renewable energy from wind, geothermal, and solar
- Demand is decreasing (negative load growth)

**NET-TO-SYSTEM GENERATION THROUGH OCT 2010
(EXCLUSIVE OF UNMONITORED DISTRIBUTED GENERATION)**



YTD HELCO Transmission-connected RE (as a % of net-to-system gen)




Reserve Policy

- Regulating reserves maintained for intra-hour frequency control.
- Contingency reserve includes offline capacity (fuel saving measure)
- Reserve down is minimal during excess energy conditions
- Reserve up may be very small during stable wind conditions (3-5 MW)
- Loss of generation events typically result in underfrequency load-shed

Distributed PV


- HELCO has had a large increase in distributed solar in the last two years
 - NEM
 - Load-offsetting PV
 - FIT (coming very soon)
- Monitoring, control, and forecasting are not available
- Impact on intra-hour variability is not known
- Apparent load (demand – distributed PV) difficult to predict

PV installations



As of 5/6/2010

PV installations as % of Annual High Peak




As of 5/6/2010

Significant DG Issues for HELCO Operations

- Displacement of generation performing critical grid services
- Adding to existing system balancing and frequency control challenges (variability)
- Adds to excess energy from non-dispatchable resources
- Lack of visibility and control
- Aggregate loss of distributed PV during faults and contingencies - nuisance trips

Frequency Bias




HELCO System Frequency

HELCO System Frequency Targets and Action Levels

| | |
|------------------|---|
| 59.95 – 60.05 Hz | Targeted Frequency Control Range |
| 59.85 - 60.15 Hz | Disturbance level: System Operator to identify cause and take corrective action |
| 59.80 – 60.20 Hz | System Alarm Level: Operator to take immediate corrective action |
| 59.5 Hz | Emergency Action Level: Mandatory manual load shed by the System Operator required if not corrected within 15 minutes |
| 59.3 Hz | Block 5 Automatic load shed if frequency remains at this level for approximately 20 seconds |
| 58.8 Hz | Block 1 instantaneous automatic load shed |
| 58.5 Hz | Block 2 instantaneous automatic load shed |
| 58.0 Hz | Block 3 instantaneous automatic load shed |
| 57.7 Hz | Block 4 instantaneous automatic load shed |


The balancing impact of wind power can be measured... and is significant...

Frequency Impact - Apollo




... the impact of distributed PV (in aggregate) is not monitored and thus unknown. We are working to gather data (discussion later).

PV & Utility Data for Large Retail
July 2, 2008




Excess Energy occurs Routinely Today, Reduced Day Peak Will have an Impact

July 24 2008 Dispatch



Excess Energy for Future Gen Mix – Distributed PV will Displace other RE

System Load 1/25/10



Distributed Solar and Excess Energy

- Provide monitoring and curtailment capabilities on the renewable energy additions. Proposed for 250 kW and larger (Interconnection rule modification).

- System Operator must be able to administer
- Need clear rules
- May be economically infeasible for small installations, such as residential PV for present methods (RTU)

- Storage may be technically feasible (centralized or distributed) but at present remains an uneconomic solution

- Distributed Solar will displace dispatchable RE to some extent


Aggregate Impact System Studies

- Studies are needed to evaluate the aggregate impact of distributed DG as it has become significant, similar to typical generator transmission interconnection study
 - Ensure generation mix provides system stability through faults and contingencies
 - Modifications to system protection including underfrequency and under voltage schemes
 - Interconnection requirements such as underfrequency and under voltage ride through
 - Operational changes necessary for secure operation (such as modification of reserves)
- Incorporate into interconnection requirements for DG (Rule 14H) - historically only considered individual project and distribution impacts

Example Completed PV Study – Impact of Aggregate Loss during Unit Trip

Figure 2 – Minimum Frequency vs. PV Penetration

Trip Puna, EPS Load Shed Scheme






Proposed Changes to DG Interconnection (Rule 14H)

- Consideration of aggregate impacts on the power system in determining additional requirements or limits
- Remote monitoring and control through SCADA/EMS (250 kW and larger)
- Provide for adjustable voltage and frequency trip settings for *all* facilities (including less than 30 kW) to reduce nuisance trips and coordinate with the underfrequency load shed scheme.
- These changes are necessary because distributed generation provides a significant amount of system generation

Other Work...

- Real-time stability data captured through use of synchrophasor data (by end of the year)
 - Detect stability issues as they emerge in real-time
 - Validate stability models to improve simulation of dynamic response
- Investigating alternative communications/controls measures for low-cost monitoring and control of DG
- Incorporate lessons learned from other high penetration areas (Europe, other islands)
- Visualization and estimation of island PV production

Real-time Irradiance and Estimated PV



Real-time Irradiance and Estimated PV

- The estimates are based on measured solar irradiance, converted to available per unit energy
- The per unit energy is used to estimate area PV production based on neighboring installed capacity
- Future work will be done to validate the estimates and/or suggest enhancements to algorithm (i.e.; smoothing or accumulating values)
- We will also work to evaluate effect on frequency control (assuming reasonableness of estimated data is verified).